



CERTIFIED MAIL  
RETURN RECEIPT REQUESTED

US EPA RECORDS CENTER REGION 5



513893

May 8, 1995

Regional Administrator  
United States Environmental  
Protection Agency, Region 5  
ATTN: Darryl Owens  
Mail Code 5HS-11  
230 South Dearborn Street  
Chicago, Illinois 60604

Director, Solid and Hazardous  
Waste Division  
Minnesota Pollution Control Agency  
ATTN: Site Response Section  
520 Lafayette Road North  
St. Paul, Minnesota 55155

Dear Sirs:

On April 24, 1995 the City of St. Louis Park (City) received an Agency letter responding to the March 15, 1995 submittal of the GAC 1994 Annual Performance Report. The letter offered two comments:

Page 3: Samples collected for acid fraction analysis per Section 4.3.4 on December 13, 1994 were incorrectly analyzed. The data is not included and, apparently duplicate samples were not taken. These analyses must be completed per Section 4.3.4 of the CD-RAP.

Page 4: Table 2 shows two columns of data for GAC treated water samples, both columns are headed Carcinogenic PAH Total. It appears that one column should be headed Other PAH Total.

The acid fraction sample including the duplicate were incorrectly prepared by the laboratory and therefore analysis for acid fraction compound could not be completed. Upon receipt of notification of this problem from the laboratory, the City collected a replacement sample on March 20, 1995. The analytical results are included in the revised report.

The column heading for Table 2 has been corrected in the revised report.

The referenced correspondence also directed the City to submit a revised 1994 Annual Performance Report. The City has enclosed for submittal the revised GAC 1994 Annual Performance Report.

Sincerely,

Scott E. Anderson  
Superintendent of Utilities

cc: William Gregg  
Elizabeth Thompson (w/o enclosures)  
Reilly File

SEAreports/usepa95